Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 31.

Dated: 28/09/2026

It is certified that an inspection team headed by ..... Jay Prakash Prasad, A E

(Name of Officers with designation) from ..P. H. Division Madhepura ~~PHED~~

inspected the ..MUMBAI INTERNATIONAL SCHOOL, MADHELI, ALAMNAGAR, MADHEPURA

(Name & Address of the school) on ..27.09.26..(date of inspection) and on the basis of

Water Test Report (Attached) bearing no..... 174 ..... dated..28.9.26

of D.L.W.T. Laboratory Madhepura ~~(PHED~~ Lab) certified that

the Mumbai International school ....(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 26.09.27

Signature with Seal: ..... Prasad 28/09/2026

Name Jay Prakash Prasad

Designation AE, P.H. Division Madhepura

Name & Address of the Office/Department ..... लोक स्वास्थ्य अभियांत्रिकी प्रमंडल, लोक स्वास्थ्य अवर प्रमंडल, (मधेपुरा)

To ....MUMBAI INTERNATIONAL SCHOOL MADHELI ALAMNAGAR MADHEPURA

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

बिहार सरकार

Government Of Bihar
Public Health Engineering Department
District Level Water Testing Laboratory Madhepura
Near T.P.College Madhepura .PHED Campus.

TC 15905
DOC NO: MDP/SAMP/05/00

TEST REPORT

Name & Address Of Customer :

Principal
Mumbai International School.
Madheli,Alamnagar , Madhepura.

ULR No:-	:	TC15905260000000174
Report No	:	MDP/W/26-27/174
Date	:	28.09.2026
Sample No	:	MDP/W/26-27/174
Sample Description	:	Drinking water
Sample Mark/Location	:	Mumbai International School
Sample Collected On	:	Sample given by school staff
Sampling Plan & Method	:	NA
Date Of Performance(S)	:	24-09-2026 to 28.09.2026
Ref No. Date	:	Ref. No. 15/MIS/26 Date 23.09.2026

Analysis Result

Sl. No.	Test Parameter	Test Method	IS:10500 : 2012 Amd.1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	Color in HU	IS 3025 (Part 4) : 2021	5	15	< 5
2	Odor	IS 3025 (Part 5) : 2022	Agreeable	Agreeable	Agreeable
3	Taste	IS 3025 (Part 8) : 2023	Agreeable	Agreeable	Agreeable
4	pH Value at 25°C	IS 3025(Part 11) : 2023	6.5-8.5	No Relaxation	7.36
5	Turbidity at NTU	IS 3025(Part 10) : 2023	1	5	1.58
6	TDS in mg/l	IS 3025(Part 16) : 2023	500	2000	168
7	Total Hardness in mg/l	IS 3025(Part 21) : 2023	200	600	97.92
8	Calcium in mg/l	IS 3025(Part 40) : 2023	75	200	29.37
9	Magnesium in mg/l	IS 3025(Part 46) : 2023	30	100	6.94
10	Iron in mg/l	APHA 23rd Edition -3500-Fe Method B (Phenonthroline Method) : 2024	1	No Relaxation	0.47
11	Chloride in mg/l	IS 3025(Part 32) : 2019	250	1000	18.21
12	Total Alkalinity in mg/l	IS 3025(Part 23) : 2023	200	600	69.36

for District Level Water Testing Laboratory,Mad6hepura
Reviewed & Authorized By
Abhayankar Katyayan
(Authorized Signatory)

* The results relate only to the item(s) tested.
* This Test Report, shall not be reproduced without, the permission of District Level Water Testing Laboratory, Madhepura.
* The reserved part of sample(s), except perishable sample(s), shall be retained for 15 days from the date of issue of the Test Report.

End of the Report.